

TEST CERTIFICATE

Stationary Tank Design

Issued pursuant to Section 82 of the Hazardous Substances and New Organisms Act 1996

This certificate is issued to:
Civilquip Limited

Certificate Number: 100111-00015234

Postal Address:
P.O. Box 391
Greymouth, 7805

Physical Address:
54 Tasman Street
Greymouth

This certificate is issued in accordance with Hazardous Substances (Dangerous Goods and Scheduled Toxic Substances) Transfer Notice 2004, Schedule 8 clause 94(1)(a).

This certifies that the relevant requirements have been met for the tank specified below:


Description	Design Specification	Tank Type
DC100 - Above Ground Integral SCS Rectangular Steel	AS 1692	Above Ground Stationary Tank

Capacity	Compartments	Substance/Classes
10,000 litres SFL		Diesel UN3082 Only; 3.1D, 6.1E, 6.3B, 6.7B, 9.1B

Conditions:

1. This certificate must be produced at the request of an enforcement officer appointed under the HSNO Act 1996.

Issued Date: 12 November 2015



Alan Mountfort
Test Certifier