

28 Ash Road  
Wiri 2104  
Auckland

# MFI

## Compliance Ltd

Hazardous Substances Compliance Specialists

P O Box 97865  
Manukau City 2241  
Auckland

### TEST CERTIFICATE

#### Stationary Tank Design

Issued pursuant to Section 82 of the Hazardous Substances and New Organisms Act 1996

**This certificate is issued to:**  
**Civilquip Limited**

**Certificate Number: 100111-16007A**

**Postal Address:**

PO Box 391  
Greymouth, 7840

**Physical Address:**

54 Tasman Street  
Greymouth, 7805

Mob: +64 21 2284427

**This certificate is issued in accordance with Hazardous Substances (Dangerous Goods and Scheduled Toxic Substances) Transfer Notice 2004, Schedule 8 clause 94(1)(a).**

This certifies that the relevant requirements have been met for the tank specified below:

Description	Design Specification	Tank Type
DCD200 Type 3 Integral SCS Rectangular Mild Steel	AS 1692	Above Ground Stationary Tank

Capacity	Compartments	Substance/Classes
19,000 litres SFL		Diesel Only UN3082 UN1202; 3.1D, 6.1E, 6.3B, 6.7B, 9.1B

**Conditions:**

1. This certificate must be produced at the request of an enforcement officer appointed under the HSNO Act 1996.

**Issued Date: 8 February 2016**

  
**Alan Mountfort**  
Test Certifier