

28 Ash Road
Wiri 2104
Auckland

MFI Compliance Ltd

P O Box 97865
Manukau City 2241
Auckland

Hazardous Substances Compliance Specialists

TEST CERTIFICATE

Stationary Tank Design

Issued pursuant to Section 82 of the Hazardous Substances and New Organisms Act 1996

This certificate is issued to:
Civilquip Limited

Certificate Number: 100111-16011A

Postal Address:

PO Box 391
Greymouth, 7840

Physical Address:

54 Tasman Street
Greymouth, 7805

Mob: +64 21 2284427

This certificate is issued in accordance with Hazardous Substances (Dangerous Goods and Scheduled Toxic Substances) Transfer Notice 2004, Schedule 8 clause 94(1)(a).

This certifies that the relevant requirements have been met for the tank specified below:

Description	Design Specification	Tank Type
DCD450 Type 3 Integral SCS Rectangular Mild Steel	AS 1692	Above Ground Stationary Tank

Capacity	Compartments	Substance/Classes
42,000 litres SFL		Diesel Only UN3082 UN1202; 3.1D, 6.1E, 6.3B, 6.7B, 9.1B

Conditions:

1. This certificate must be produced at the request of an enforcement officer appointed under the HSNO Act 1996.

Issued Date: 8 February 2016



Alan Mountfort
Test Certifier

Ph: +64 9 2638371
Fax: +64 9 2638372
Email: Office@mfi-compliance.co.nz