

28 Ash Road  
Wiri 2104  
Auckland

# MFI Compliance Ltd

Hazardous Substances Compliance Specialists

P O Box 97865  
Manukau City 2241  
Auckland

## TEST CERTIFICATE

### Stationary Tank Design

Issued pursuant to Section 82 of the Hazardous Substances and New Organisms Act 1996

**This certificate is issued to:**  
Civilquip Limited

**Certificate Number: 100111-00016142**

**Postal Address:**

PO Box 391  
Greymouth, 7840

**Physical Address:**

54 Tasman Street  
Greymouth, 7805

Tel: +64 3 9745516  
Mob: +64 21 2284427

**This certificate is issued in accordance with Hazardous Substances (Dangerous Goods and Scheduled Toxic Substances) Transfer Notice 2004, Schedule 8 clause 94(1)(a).**

This certifies that the relevant requirements have been met for the tank specified below:


Description	Design Specification	Tank Type
DC25 Type 3 Double skinned Integral SCS Rectangular Mild Steel	AS 1692	Above Ground Stationary Tank

Capacity	Compartments	Substance/Classes
2,375 litres SFL		Diesel only, UN3082, UN1202; 3.1D, 6.1E, 6.3B, 6.7B, 9.1B

**Conditions:**

1. This certificate must be produced at the request of an enforcement officer appointed under the HSNO Act 1996.

**Issued Date: 24 August 2016**

  
\_\_\_\_\_  
**Alan Mountfort**  
Test Certifier

Ph: +64 9 2638371  
Fax: +64 9 2638372  
Email: Office@mficompliance.co.nz